

Snell & Wilmer
L.L.P.
LAW OFFICES

One Arizona Center
400 East Van Buren Street
Suite 1900
Phoenix, Arizona 85004-2202
602.382.6000
602.382.6070 (Fax)
www.swlaw.com
Bradley S. Carroll
Counsel
602.382.6578
bcarroll@swlaw.com

ORIGINAL



0000121890

RECEIVED

2011 JAN 10 P 3:39

ARIZONA CORPORATION COMMISSION
DOCKET CONTROL

LOS CABOS
ORANGE COUNTY
PHOENIX
SALT LAKE CITY
TUCSON

January 10, 2011

VIA EMAIL AND HAND-DELIVERY

Margaret Little
Utilities Division
Arizona Corporation Commission
1200 West Washington Street
Phoenix, Arizona 85007

Wesley Van Cleve, Staff Counsel
Legal Division
Arizona Corporation Commission
1200 West Washington Street
Phoenix, Arizona 85007

Re: **Sulphur Springs Valley Electric Cooperative, Inc ("SSVEC")
Supplemental Responses to Staff's Second Set of Data Requests
Dated November 23, 2010
Docket No. E-01575A-10-0311**

Dear Ms. Little and Mr. Van Cleve:

Enclosed are SSVEC's Supplemental Responses to TL 2.3 and TL 2.4 to Staff's Second Set of Data Requests in the above-reference docket. These Responses are also being provided to you electronically via e-mail.

Please do not hesitate to contact me if you have any questions.

Sincerely,

Snell & Wilmer L.L.P.

Bradley S. Carroll

BSC/dcp

Enclosure

cc: Kirby Chapman. SSVEC

Arizona Corporation Commission
DOCKETED

JAN 10 2011

DOCKETED BY

**SUPPLEMENTAL RESPONSES OF SULPHUR SPRINGS VALLEY
ELECTRIC COOPERATIVE TO STAFF'S SECOND SET OF
DATA REQUESTS
DOCKET NO. E-01575A-10-0311**

November 23, 2010

TL 2.3 **Please provide the average power factor for the distribution system for each of the past five years (2005-2010).**

Initial Response: This data is stored in SSVEC's and also on SWTC's SCADA systems. As of December 2, both SCADA systems are unavailable due to software upgrades being installed. When a system is available, SSVEC will respond to this request. We expect these systems to be available again by December 20, 2010

Supplemental Response: The requested information is only available for the last three (3) years, as follows:

2008	99.65%
2009	99.65%
2010	99.75% [until Oct 31]

Prepared by: Anselmo Torres, Chief Engineering and Operations Officer
Sulphur Springs Valley Electric Cooperative, Inc.
850 N. Haskell
Willcox, Arizona 85644

**SUPPLEMENTAL RESPONSES OF SULPHUR SPRINGS VALLEY
ELECTRIC COOPERATIVE TO STAFF'S SECOND SET OF
DATA REQUESTS
DOCKET NO. E-01575A-10-0311**

November 23, 2010

TL 2.4 Please provide the system power factor for the peak hour for each of the past five years.

Initial Response: This data is stored in SSVEC's and also on SWTC's SCADA systems. As of December 2, both SCADA systems are unavailable due to software upgrades installed. When a system is available, SSVEC will respond to this request. We expect these systems to be available again in December 20, 2010.

Supplemental Responses: The requested information is only available for the last three (3) years, as follows:

2008	97.37%
2009	97.32%
2010	98.12%

Prepared by: Anselmo Torres, Chief Engineering and Operations Officer
Sulphur Springs Valley Electric Cooperative, Inc.
850 N. Haskell
Willcox, Arizona 85644